



March 13, 2018

Dear Bidders

RE: Swing Bridge and Longbird Bridge Ground Investigations

The Government of Bermuda, Ministry of Public Works has received the following question from interested bidders and offers the following answers that will form Addendum 1.

The following addendum supersedes information contained in drawings and specifications issued for this project to the extent referenced. This addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.

1. With regard to the rotary core drilling specifications; the specifications state that a core size of 102 mm (S w/l) is required. This size coring equipment is not available on the Island and is cost prohibitive to obtain. We have P w/l (83mm) and H w/l (61.1mm) sized coring systems on the Island and available for use. Can the specifications for this investigation could be changed to allow P or H sized rotary coring?
 - Response: Yes, a reduction in core barrel to P w/l (83mm) is acceptable for this project. Amend clause S1.10.4 to include this change.

Please note that all addenda will be posted on the Governments Procurement Notice Site, www.gov.bm .