



Government of Bermuda
Ministry of Public Works
Department of Works and Engineering

Addenda
For
Gibbs Hill Light House Internal Painting

Procurement No.: **2023-008Q-MPW**

Issued: **February 5, 2024**

Submission Deadline: **March 4, 2024, 03:00 P.M.**

Addenda No. **0001**

Addenda Type: Questions and Responses

The following addendum supersedes information contained in the solicitation document issued for this procurement to the extent referenced. This Addendum forms part of the solicitation documents and will be subject to all the conditions set out in the contract conditions.

Bidder's Questions (Q) and Government's Responses ® are shown below.

Q 1. Is a two-part epoxy system for the metal floors and stairs acceptable.

A 1. No, a two-part epoxy system is not acceptable. The main concerns being the respect of the high VOC's and poor ventilation, which would necessitate the use of respirators, as well as an increased risk of this product failing to adhere to the existing finishes.

End of Addenda No:0001