

Bermuda Fire and Rescue Service
15 Wallers Point Road, Southside, St. Davids DD03, Bermuda
Tel: (441) 292-5555 Fax: (441) 295-2316 Email: fireprotection@gov.bm

FIRE CERTIFICATE APPLICATION

APPLICATION FEE: _____
ADDRESS OF SITE _____

- Class A Building
- Class B Building
- Class C Building

OFFICE USE:
CERTIFICATE NO. _____
File Number: _____

NAME OF BUILDING: _____ BUILDING NO. _____

STREET _____ PARISH _____ POSTCODE _____

PROPOSED WORK

ADDITIONS ALTERATIONS CHANGE OF USE NEW CONSTRUCTION DEMOLITION OTHER

GIVE DETAILS _____

USE GROUP _____ CONSTRUCTION TYPE _____ SITE AREA _____ (sq ft)

EXISTING SITE COVERAGE _____ ADDITIONAL SITE COVERAGE _____ TOTAL SITE COVERAGE _____ (sq ft)

EXISTING FLOOR AREA _____ ADDITIONAL FLOOR AREA _____ TOTAL FLOOR AREA _____ (sq ft)

ARE ANY OTHER PERMITS ACTIVE AT THE PROPERTY? _____ IF YES, LIST NOS _____

APPLICANTS (OWNERS) NAME _____

ADDRESS _____

PHONE _____ (H) _____ (W) EMAIL _____ POST CODE _____

AGENT'S NAME _____

ADDRESS _____ EMAIL _____ POST CODE _____

PHONE _____

DOCUMENT SUBMISSION *for new construction only

Enclosed are 4 sets of Bound Constructions documents each consisting of _____ pages of drawings numbered _____ and dated _____ (please ensure that all drawings submitted for permit are marked "for permit" and are stamped and signed by the local registered engineers where applicable).

*APPLICANT'S SIGNATURE _____ DATE _____

***If signed by anyone other than the Owner, this application must be accompanied by a letter from the Owner stating that he or she agrees to the proposals being carried out.**

Pursuant to the Fire Safety Act 2014, I hereby apply for Fire Certificate for the project described. I request that my certificate if granted list any additional requirements which are not shown on my documents and hereby consent to any such requirements, and agree to fully comply. I further certify that I will perform no work on the property not specifically described in the application, and grant officials the right to enter onto the property to inspect the premise.

OFFICE USE ONLY:	
RECEIVED ON _____	BY _____
RECEIPT YES <input type="checkbox"/> NO <input type="checkbox"/>	
DOCUMENTS APPROVED	
By _____	Date _____

Conditions: All of the certificate conditions on the back of this page plus the following:

Inspection Completed _____ Plans Examiner _____

By _____ Date _____
Fire Inspector

Date of Certificate Issued _____

Signature of Recipient _____

Print Name _____

Exit Signs

Exit signs with not less than 6" green block letters and principle strokes 3/4" wide shall be provided over all exits.

Fire Alarm System

The fire alarm system shall be installed in accordance with:

- a. NFPA 70 - National Electrical Code
- b. NFPA 72 – National Fire Alarm and Signaling Code.

Sprinkler System and Fire Pump

The Sprinkler System and Fire pump installation shall be in accordance with:

- a. NFPA 13 – Installation of Sprinkler Systems
- b. NFPA 13R – Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies
- c. NFPA 13D - Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings
- d. NFPA 14 – Installation of Standpipes and Hose Systems
- e. NFPA 20 – Installation of Stationary Pumps
- f. NFPA 25 – Inspection, Testing and Maintenance of Water Based Fire Protection Systems.

All Engineered sprinkler systems shall be stamped by a local Registered Engineer.

Electrical Wiring Installation

All electrical wiring and equipment installed shall be in accordance with NFPA 70 - National Electrical Code.

Heating, Ventilation and Air Conditioning

The air conditioning, ventilation or heating ducts etc. shall be installed in accordance with:

- a. NFPA 90A – Standard for the Installation of Air-Conditioning and Ventilating Systems
- b. NFPA 90B – Standard for the Installation of Warm Air Heating and Air-Conditioning Systems

Commercial Cooking Equipment

The design, installation, operation, inspection, and maintenance of all public and private cooking operations shall be in accordance with NFPA 96 – Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.

LPG Installation

The LPG installations and cylinders shall be in accordance with NFPA 58 – Liquid Petroleum Gas Code.

Fixed Fire Suppression System

The installation, maintenance and testing of Fixed Fire Suppression systems provided shall be in accordance with:

- NFPA 12-Standard on Carbon Dioxide Extinguishing Systems
- NFPA 12A - Standard on Halon 1301 Fire Extinguishing Systems
- NFPA 17 – Standard for Dry Chemical Extinguishing Systems
- NFPA 17A – Standard for Wet Chemical Extinguishing Systems
- NFPA 2001 - Standard on Clean Agent Fire Extinguishing Systems

Any alterations or amendments to the submitted drawings will render this approval invalid.