



**Estates Section**

**Request for Proposal ADDENDUM No. 1**

---

**DATE:** June 6, 2023 **METHOD OF DELIVERY:** GOV. WEBSITE  
**PROJECT NAME & NO.:** Royal Bermuda Regiment Washroom Reno. Project  
**RE:** Tender Documents  
**TO:** All Proponents

---

*The following information supplements and/or supersedes the RFP documents dated May 23, 2023*

*This RFP Addendum forms part of the contract documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original documentation issued for the above named project to the extent referenced and shall become part thereof. Acknowledge receipt of this RFP Addendum by inserting its number and date on the RFP Form. Failure to do so may subject the Proponent to disqualification.*

**No. : DESCRIPTION:**

1. There will be a washroom identified for the General Contractor to use; at the end of day cleanliness is required by the General Contractor.
2. Existing Roof - Pressure Wash/Clean with manufactures recommended solvent - clean roof so that its free of debris, dirt, organic matter (fungal growth) to receive crack sealant/paint as per Manufactures specifications; make all repairs as needed to the roof area of building prior to painting; apply two (2) coats of an Elastomeric (SKB) type paint/sealer, white in color, and must be compatible with existing roofing material.
3. Existing Men’s Washroom - All wall tile and cove base tile shall be removed with existing walls made good and prepared for new floor tile; all floor tile shall remain and made good were necessary to received new floor tile; new floor tile to be installed per specification

End of RFP Addendum 1